

# SANS Industrial Control Systems Security Blog

09 Jan 2016

## Confirmation of a Coordinated Attack on the Ukrainian Power Grid

[3 comments](#) Posted by [robertmlee](#)  
Filed under [Security Awareness](#)

This post was written by Michael J. Assante, SANS ICS Director:

After analyzing the information that has been made available by affected power companies, researchers, and the media it is clear that cyber attacks were directly responsible for power outages in Ukraine. The SANS ICS team has been coordinating ongoing discussions and providing analysis across multiple international community members and companies. We assess with high confidence based on company statements, media reports, and first-hand analysis that the incident was due to a coordinated intentional attack.

The attackers demonstrated planning, coordination, and the ability to use malware and possible direct remote access to blind system dispatchers, cause undesirable state changes to the distribution electricity infrastructure, and attempt to delay the restoration by wiping SCADA servers after they caused the outage. This attack consisted of at least three components: the malware, a denial of service to the phone systems, and the missing piece of evidence of the final cause of the impact. Current evidence and analysis indicates that the missing component was direct interaction from the adversary and not the work of malware. Or in other words, the attack was enabled via malware but consisted of at least three distinct efforts.

### The Multiple Elements

The cyber attack was comprised of multiple elements which included denial of view to system dispatchers and attempts to deny customer calls that would have reported the power out. We assess with high confidence that there were coordinated attacks against multiple regional distribution power companies. Some of these companies have been reported by media to include specifically named utilities such as Prykarpattiaoblenergo and Kyivoblenergo. The exact timeline for which utilities were affected and their ordering is still unclear and is currently being analyzed. What we do know is that Kyivoblenergo provided public updates to customers, shown below, indicating there was an unauthorized intrusion (from 15:30 — 16:30L) that disconnected 7 substations (110 kV) and 23 (35 kV) substations leading to an outage for 80,000 customers.

12/24/2015

### Dear customers!

**Dec. 23, 2015, from 15:35 - 16:30,** third parties were made illegal entry into information-technological system of remote access to equipment telecontrol substations of 35-110 kV JSC "Kyivoblenergo."

As a result, it was disconnected 7 (seven) 110 kV substations and 23 (twenty three) substation 35 kV. This led to the repayment of about 80,000 different categories of customers on the reliability of electricity supply.

Electricity was restored to all consumers employees of the Company at **18:56** the same day.

We apologize for the situation and thank you for your understanding.

PJSC "Kyivoblenergo"



RSS

Search

### Categories

- [Courses](#) (2)
- [Defense Use Cases](#) (1)
- [ICS Survey](#) (2)
- [Instructors](#) (3)
- [Internet of Things](#) (2)
- [IT-OT Convergence](#) (3)
- [NERC CIP v5](#) (1)
- [Security Awareness](#) (9)
- [Summit](#) (1)
- [Uncategorized](#) (0)

### Recent Posts

- [Confirmation of a Coordinated Attack on the Ukrainian Power Grid](#)
- [ICS Cross-Industry Learning: Cyber-Attacks on Electric Transmission and Distribution \(Part One\)](#)
- [Potential Sample of Malware from the Ukrainian Cyber Attack Uncovered](#)
- [Current Reporting on the Cyber Attack in Ukraine Resulting in Power Outage](#)
- [Takeaways from Reports on Iranian Activity Against the Power Grid and a Dam](#)

### Recent Comments

### Popular Posts

### Archives

Select Month

### Links

- [Log in](#)
- [Entries RSS](#)
- [Comments RSS](#)


The key significance here is that 80,000 customers comprise a significant portion of their residential load. Power was restored to all customers by (18:56L). They also reported technical failures with their call line interfering with receiving customer's calls as shown below.

12/24/2015

## Dear customers!

23 December 2015 there was a technical failure in the infrastructure, making it difficult to dial call center PJSC "Kyivoblenergo."

We apologize for any inconvenience.



Quick action by utility staff to switch to "manual mode" and restore the system was impressive. Statements from utility staff to local media indicated the distribution system was being run without the benefit of their SCADA as it was still infected. Field staff at the impacted power companies manned required substations, transferring from "automatic to manual mode", and manually re-closed breakers to energize the system. Restoration varied but all services were restored in 3-6 hours. It is important to note that there are risks operating your system without the benefit of an automated dispatch control center and utilities that are more reliant on automation may not be able to restore large portions of their system this way. In many ways, the Ukrainian operators should be commended for their diligence and restoration efforts.

### Cyber Attack Milestones as Reported To Date:

From what has been reported, here is the information to date that we are confident took place. The exact timing of the events is still being pieced together.

- The adversary initiated an intrusion into production SCADA systems
- Infected workstations and servers
- Acted to "blind" the dispatchers
- Acted to damage the SCADA system hosts (servers and workstations)
  - Action would have delayed restoration and introduce risk, especially if the SCADA system was essential to coordinate actions
  - Action can also make forensics more difficult
- Flooded the call centers to deny customers calling to report power out

### Probable Cyber Attack Milestones as Reported to Date:

In analyzing the evidence and reports there are still missing pieces to the attack. Understanding the initial foothold of the adversary, the eventual impact, and the types of systems in place can help to make assessments on what the adversary likely had to have done but the items stated below are currently probable and not known. We are working to verify and uncover more information.

- The adversaries infected workstations and moved through the environment
- Acted to open breakers and cause the outage (assessed through technical analysis of the Ukrainian SCADA system in comparison to the impact)
- Initiated a possible DDoS on the company websites

### Malware Enabled but Not Likely Malware Caused

It is interesting and important to understand the role of the malware sample SANS ICS [previously reported](#) that came from one of the infected networks. There have been two prominent theories in the community and speculation to the media that either the 'KillDisk' component was just inside the network and unrelated to the power outage (a reliability issue where malware just happened to be there) or that the 'KillDisk' component was directly responsible for the outage. It is our assessment that neither of these are correct. Malware likely enabled the attack, there was an intentional attack, but the 'KillDisk' component itself did not cause the outage.

It is also important to note that many of the samples being analyzed in the community to date as reported by others are not guaranteed to have been involved in this incident. The malware campaign reported, tied to BlackEnergy and the Sandworm team by others, has solid links to this incident but it cannot be assumed that files such as the excel spreadsheet and other malware samples recovered from other portions of that campaign

were at all involved in this incident. It is possible but far too early in the technical analysis to state that. The type of analysis being done by the security researchers and companies assessing this is valuable analysis and they should be commended. At the worst it will provide lessons learned and training opportunities for the community. But analysts should be careful not to overstate current analysis of malware samples due to their link to the larger campaign as being specific to this incident. Simply put, there is still evidence that has yet to be uncovered that may refute the minutia of the specific components of the malware portion of the attack.

More importantly, the link of the 'KillDisk' wiper to the actual cause of the outage is not likely. This is stated because power systems and SCADA schemes simply do not work in that manner. In other words, the incident observed with consideration to timing, sites, and impact does not at all align with the narrative of the 'KillDisk' component itself causing the impact. I have observed the loss of many SCADA systems for periods of time that resulted in no outage or impact to the power system. Running a power system without the benefit of your SCADA system at the distribution-level adds risk, but without something to change the 'state' (for example to force a circuit to de-energize) then the system will continue to serve power. We assess currently that the malware allowed the attackers to gain a foothold at the targeted utilities, open up command and control, and facilitate the planning of an attack by providing access to the network and necessary information. The malware also appears to have been used to wipe files in an attempt to deny the use of the SCADA system for the purposes of restoration to amplify the effects of the attack and possibly to delay restoration.

### Final Thoughts

We are very interested in helping power utilities learn as much as they can from this real world incident. We would also note the competent action by Ukrainian utility personnel in responding to the attack and restoring their power system. As a community the power industry is dedicated to keeping the lights on. What is now true is that a coordinated cyber attack consisting of multiple elements is one of the expected hazards they may face. We need to learn and prepare ourselves to detect, respond, and restore from such events in the future. The SANS ICS team will be continuing our analysis and presenting findings and updates to the community in multiple formats. On Jan 20<sup>th</sup> we will host a webcast focusing on understanding the industrial control systems and SCADA networks of the Ukrainian power grid to identify what was even possible in terms of attack scenarios. Following that, we will release more information at the [SANS ICS Summit](#) with a full breakdown of what we know and its value to the community. Finally, we will be releasing a comprehensive whitepaper on the incident in our Defense Use Case (DUC) series in our [ICS Digital Library](#). The DUC will highlight both the cyber and physical components to this incident and the lessons learned for the community.

We sincerely thank all the effort going on in the community by numerous passionate researchers and companies across both the information technology and the ICS community. It takes all of us working together to understand and respond to these types of incidents.

**Bio:** Michael Assante is currently the SANS lead for Industrial Control System (ICS) and Supervisory Control and Data Acquisition (SCADA) security and co-founder of NexDefense an Atlanta-based ICS security company. He has also served as CSO of NERC, several high-level positions at Idaho National Labs, and CSO of American Electric Power.



[Permalink](#) | [Comments RSS Feed](#) - [Post a comment](#) | [Trackback URL](#)

## 3 Comments

Posted January 09, 2016 at 10:57 PM | [Permalink](#) | [Reply](#)

Chris Wolski

Thanks for keeping this real and up to date.

Posted January 10, 2016 at 3:27 PM | [Permalink](#) | [Reply](#)

Jake Brodsky

I wouldn't be so quick to dismiss the wiper component, Mike. If I were trying to shut down a grid to where black-starts would be needed, I would first trip a series of breakers and then I would kill the SCADA system to prevent it from being used for the recovery.

Posted January 10, 2016 at 6:21 PM | [Permalink](#) | [Reply](#)

Jake, that is actually consistent with our current analysis. Mike and the team aren't dismissing that the wiper was involved in the attack (thus the malware enabled but not malware caused comment). It very likely was used to blind the operators and delay restoration efforts. But the wiper itself did not cause the outage. There are a lot of folks in media stating that the wiper itself could have caused the power outage and impact - that is just not a consistent narrative with what has been observed. We entirely agree with you that KillDisk played a role in the amplifying effect though.

## Post a Comment

**\*Name**

**\*Email**

**Website**

**\*Comment**

**Captcha**



**\*Response**

Post Comment

\* Indicates a required field.

### Latest Tweets @SANSICS

[Announcing the new #BETA SANS Course : #ICS456 - Essentials \[...\]](#)

January 14, 2016 - 3:16 PM

[The ICS-CERTs latest report notes that BlackEnergy3 was cont \[...\]](#)

January 13, 2016 - 6:25 PM

[New from @SANSICS blog: "Confirmation of a Coordinated Attac \[...\]](#)

January 9, 2016 - 10:26 PM

### Latest Papers

[Testing stateful web application workflows](#)

By Andras Veres-Szentkiralyi

[Burp Suite\(up\) with fancy scanning mechanisms](#)

By Zoltan Panczel

[Applying Data Analytics on Vulnerability Data](#)

By Yogesh Dhinwa

"The depth of knowledge I'm taking away from the SCADA conference would have taken two or three other training conferences offered from other

"The SCADA Summit series provide a valuable combination of discussion on real world challenges and suggestions on how to resolve them."

"This was a great opportunity to gain knowledge on securing a control system from external threats"  
- Danny Carlsen, MacAulay-Brown

providers."

- John Mathias, Owens Corning

- Tony Risinger, Westar Energy



Industrial  
Control  
Systems



[Resources](#) | [Courses](#) | [Events](#) | [Certification](#) | [Instructors](#) | [About](#)

© 2011 - 2016 SANS™ Institute